City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org - Website: www.cityofbullshoals.org

Phone: (870) 445-4775 - Fax: (870) 445-4948

June 20, 2023

Council Meeting Notes

WATER DEPARTMENT

One Calls

Normal- 18

Emergency- 2

Service Orders

New Installations-	1
Out-	1!
Transfer From-	0
Transfer To-	0
Disconnect for Non-Payment-	0
Reconnect from Non-Pay-	0
Vacation Reconnect-	0
Vacation Disconnect-	0
Location-	4
New Water/Sewer Connection-	0

Alteration orders-64

. · · · · · · · · · · · · · · · · · · ·	
Leak Checks-	4
Lock off -	2
ERT Swaps-	4
ERT Swap with leak Sensor-	4
Meter Checks-	4
Meter Pulled/Swap-	2
Meter box Check-	2
Turn off-	. 2
Turn on -	1
Meter stop replacement-	Ò
Meter/Manhole Replace/Repair	- 1
Valve replacement-	1

Water Clerk Alterations (Mailing address change, or phone number)-37

Miscellaneous Notes

Thanks,

Roger Edkin/DH

BULL SHOALS WATER & SEWER Service Order Summary
From 05/17/2023 To 06/20/2023
Key Word:

11:57:22 AM

S.O. Description

New Installation

Out

Alteration Location

S.O. Type

l Ö

Α

6/20/2023

[Key Word] Comment Count Count 10 15 64

Page

10 of

Bull Shoals wastewater monthly report

- Lift station #6 went down, called Jack Tyler Engineering
- Jack Tyler couldn't figure it out had to rent bypass pump from velocity
- Locate sewer tap on Autumnwood Drive
- Did Two one-calls, while roger was at class. Woodstone Road and Winterview Drive.
- Empty drying beds and filled sludge dumpster.
- One sludge dumpster hauled off.
- One vac trailer call-out for water leak on Brown's Beach Road.
- General maintenance of lift stations and sewer plant
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 5,302,000 gallons in May

Thank You,

Micheal Salentine

(Any Questions call me @ 1(870)421-0842)

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org - Website: www.cityofbullshoals.org

Phone: (870) 445-4775 - Fax: (870) 445-4948

June 20, 2023

Council Meeting Notes

STREET DEPARTMENT

Fixed brush hog, currently brush hogging sides of roads
Replaced ballast lighting in Dam Site office
Filled various pot holes with asphalt and resurfaced Sandot and Margarets Lane
Put in new support and rehung chain at Browns Beach
Put backup alarm on small dump truck as per safety check
Found problem on brush hog to be gas cap, ordered one and now its on
Had bumper on 3500 truck and deck on mower 2 ordered
Cleared broken poles of fence down n Rivercliff
Laid big rock in area on Alford where 3 ditches come into one culvert

WORKING ON AT PRESENT TIME

Brush hogging entire city Cleaning culverts Clearing blocked street and stop signs

ANIMAL CONTROL

0 at this time

RECYCLING

38 bales of cardboard

4 paper

3 clear

2 milk

1 baler inoperable

Thanks, Ed Martin/DH